

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0559:132 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Brian Foltz *(763) 493-6400

DESIGN: Models SD500-FRCM, SD500-FRCM-4 Monitor Modules and Model SD505-ARM Relay Module.

Models SD500-ARM, SD500-AIM, SD500-MIM Addressable Input Modules.

Models SD500-FRCM and SD500-FRCM-4 monitor modules provide inputs for a control unit communication circuit and one Style B (Class B) contact closure initiating device circuits.

Models SD505-ARM and SD500-ARM provide inputs for a control unit communication circuit and have two sets of dry relay contacts. Models SD500-AIM and -MIM provide additional input circuits.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: SD500-FRCM, -FRCM-4, -ARM, -AIM, -MIM: 24 VDC
SD505-ARM: 120 VAC, 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with Silent Knight's separately listed Model 5820 fire alarm control unit (CSFM Listing No. 7165-0559:130).

XLF: 7300-0410:145

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 17, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy
Program Manager**